STEAM ASSOCIATION OF MANITOBA

Steam Gauge Verification Record Exhibit 12 (Rev A)

Gauge Identification

SAM 22-06 Make WINTERS Serial# —

Gauge Max 200 Owner MAM REEVES

Engine/Boiler _____ MB BB# 6652 MAWP 115

Notes _____

Comparison

Date JUNE 23/22 Personnel JIM DOWN / MIKE HAWKINS

Lifts at (PSI) 5 Test max PSI 150 (MAWP × 1.25)

Rising Pressure				Falling Pressure			
Calibrated Gauge	Field Gauge	Calibrated Gauge	Field Gauge	Calibrated Gauge	Field Gauge	Calibrated Gauge	Field Gauge
10	11	160		10	12	160	
20	20	170		20	22	170	
30	30	180		30	32	180	
40	40	190		40	42	190	
50	50	200		50	54	200	
60	60	210		60	64	210	
70	70	220		70	74	220	
80	80	230		80	82	230	
90	90	240		90	92	240	
100	100	250		100	102	250	
110	110	260		110	112	260	
120	120	270		120	122	270	
130	131	280		130	132	280	
140	141	290		140	142	290	
150	152	300		150	152	300	