

STEAM ASSOCIATION OF MANITOBA

Steam Gauge Verification Record

Exhibit 12 (Rev D)

Gauge Identification

SAM ID 26-07 Make ASH CROFT Serial# 357-832
 Gauge Max 250 Owner MAN
 Engine/Boiler 110 CASE MB B# B 6650 MAWP 124

Notes _____

Comparison

Date MAY 30/26 Personnel _____
 Lifts at (PSI) 5 Test max PSI 160 (MAWP × 1.25)

Rising Pressure				Falling Pressure			
Field Gauge (Set)	Master Gauge (Read)	Field Gauge (Set)	Master Gauge (Read)	Field Gauge (Set)	Master Gauge (Read)	Field Gauge (Set)	Master Gauge (Read)
0	5	160	163	0	3	160	163
10	8	170		10	8	170	
20	18	175		20	18	175	
25	24	180		25	23	180	
30	30	190		30	28	190	
40	40	200		40	38	200	
50	50	210		50	48	210	
60	61	220		60	60	220	
70	71	225		70	70	225	
75	76	230		75	75	230	
80	81	240		80	80	240	
90	91	250		90	90	250	
100	102	260		100	100	260	
110	112	270		110	112	270	
120	122	275		120	122	275	
125	128	280		125	127	280	
130	133	290		130	133	290	
140	143	300		140	142	300	
150	153			150	152		

Revision Date
June 22, 2024